



Open isolation valve.

Increase water flow rate or pressure through system.

2 meters minimum required.

Do not use other water outlets when using the taps.

Flush through pipework to ensure removal of debris and any airlocks.

This is caused by capilary action, the build up of water in the tap body.

Remove valves and clean, refer to 'Maintenance' section before starting any maintenance.

Open isolation valve.

Turn on mains water supply.

